## **Required Inspections For Swimming Pools**

Handout No. 3-3 Published: 8/21/00 Page 1 of 2 Revised 5-1-04

<u>Typical swimming pool inspections</u> include the following six inspections:

- 1. <u>Underground Electrical Inspection</u> This inspection occurs after the underground electrical conduits have been installed. All work shall be left completely exposed until after the inspection has been approved.
- 2. <u>Underground Plumbing Inspection</u> This inspection occurs after gas and/or water lines are installed and prior to backfill. When gas lines are installed, they shall be tested with air. Piping up to 1 1/4", the test shall hold 10 psi for 15 minutes with a 30 lb. test gauge. For gas piping 1 1/2" and larger, the test gauge must be with a mercury gauge (manometer) and shall hold a 10-inch column of mercury.
- 3. <u>Pre-Gunite Inspection</u> This inspection occurs after the pool has been excavated and all reinforcement steel has been installed. Setbacks are checked at this time. Also, forming shells of light niche fixtures with extended raceway shall be installed and shall be bonded to the reinforcement steel at this inspection. All bond tails to be installed, including bonds to forming shells. A preliminary check of overhead wire clearances is made at this time.
- 4. **Potting Inspection** This inspection occurs after the pool is gunited. Light fixtures shall be placed on top of the pool deck coving. A No.8 copper insulated ground wire is required at all light fixtures and shall terminate at the inside of the forming shell. The ground terminal on the light fixture shell shall be coated with a UL *listed* potting compound. The potting compound package shall be left next to the light fixture so the inspector can verify that the compound used is an appropriate type.
- 5. <u>Pre-Deck Inspection</u> This inspection occurs after the deck reinforcing steel has been installed and prior to concrete placement of the pool deck. The pool deck steel reinforcement must be tied together with tie wires at all rebar intersections and ties shall be wrapped tightly. Reinforcing steel or metal wire mesh shall be bonded to bond coil originating from the forming shell.
  - Note: The code requires that <u>all metal within 5 feet of the water's edge</u> be bonded together unless separated by a permanent barrier. <u>Examples of items that are required to be bonded are</u>: pool equipment motors, metallic pool equipment (such as filter housing), steel reinforcement (rebar), deck steel (rebar), forming shells (housing light fixtures), diving boards, slides, ladders, pool cover motors, metallic fences, etc. Bonding clamps must be installed per their listing. Bonding clamps for direct burial or concrete encasement shall be brass, copper, or copper alloy.

<u>Note:</u> The prime reason for grounding metal parts is to bring all metal parts around the pool to ground potential and thus reduce the threat of shock hazard.

- 6. <u>Pre-Plaster Inspection</u> This inspection verifies that all safety features of the pool, including the required enclosure, are complete before the pool is plastered and ready for water. If the pool project is complete (except for plastering) at this inspection, this will be the Final Inspection (see below), the permit will be approved as Final and the inspection process will be complete.
- 7. **<u>Final Inspection</u>** (may be concurrent with Pre-Plaster Inspection, see above) This inspection occurs after all other required inspections have been signed off. The following items will be verified:
  - Safety Enclosure is mandatory and must be installed per city requirements.
    Note: A <u>handout</u> is available at the Building Division Permit Center, which describes pool fence enclosure requirements. Please follow it carefully.
  - 2. Pool re-fill piping (if installed) must have appropriate back flow device per UPC section 603.4.5.
  - 3. Glass in windows and doors within 5 feet of the edge of the pool must be safety glazing.
  - 4. At least one <u>electrical receptacle</u> shall be installed outdoors between ten and twenty feet of the pool's edge. This receptacle shall be protected with a Ground Fault Circuit Interrupter (GFCI). Also, no electrical outlets are allowed less than 10 feet from the pool.
  - 5. GFCI protection of required lights, receptacles and hot tubs.
  - 6. Junction box clearances min. 8 inches above water; min. 4 inches above the deck; min. 4 feet from the water's edge.
  - 7. Pool equipment subpanel listed & installed per listing and code.
  - 8. Pool equipment to be bonded.
  - 9. Main electric panel checked for sizing adequacy.
    - <u>Note</u>: <u>Load calculations are required if</u> the main electric panel is rated for 100 amps or less and there is a spa <u>and A/C</u> unit.
  - 10. Overhead wire clearances Per the Electric Code.
  - 11. Pool and Spa Heating Systems meet California Energy Requirements.

The following five items are mandatory per the Energy Code:

- A. At least 36 inches of pipe between filter & heater for future solar heating.
- B. Cover for heated outdoor pools and outdoor spas.
- C. Heating System is certified with 78% thermal efficiency; has on/off switch; and weatherproof operating instructions.
  - **Note:** Electric Resistance Heating and gas pilot lights are not allowed.
- D. Directional inlets that adequately mix the pool water.
- E. Circulation pump must have a time switch.

Note: Swimming pool plumbing systems are closed systems and are not regulated in the Plumbing Code and, therefore, are not inspected by the Building Division. However, when a water pipe inlet is installed to re-fill a pool, it must comply with backflow requirements per the Plumbing Code (UPC).

<u>Note:</u> For <u>public</u> swimming pools, contact the Santa Clara County Health Department for additional requirements. Their phone number is (408) 299-6074.

Additional information can be obtained by visiting our website at <a href="www.sanjoseca.gov/building/">www.sanjoseca.gov/building/</a> or by calling our Information Inspector's voice mail at (408) 535-3555 and leaving a detailed message. In addition you may visit the Building Division in City Hall at 200 East Santa Clara St. Our hours are 9:00 a.m. to 4:00 p.m. with limited service between 12:00 p.m. and 1:00 p.m.

